



ALL PIPES PASSING THRU A HOLE ARE LEVEL WITH THE WALL OF THE PIPE TO WHICH THEY ARE BRAZED +/- 1/8"

	SKILL 38 – REFRIGERATION & AIR CONDITIONING	
	SUCTION ACCUMULATOR DRAWING	
	DATE: MAY 12, 2021	