



**SkillsCompétences**  
Canada  
Winnipeg2023



# PROFESSIONAL PRACTICE








## Mechatronics


# POST-SECONDARY

## 0. Guidelines

0. GUIDELINES	3 POINTS:	2 POINTS:	1 POINT:	0 POINTS:
	excellence	Professional / Still acceptable (~80% Solution)	Optimization / rework necessary	Not acceptable
Guidelines for marking the aspect – Step 1	ok		not ok	
Guidelines for marking the aspect – Step 2	If all conditions below are fulfilled. To award a mark less than 3 the experts must show the competitors what they need to improve.	If there are one or a few minor deviations.	If there is a major deviation or more than a few minor deviations.	If the work is far from the standard specified.









# 1. Cleanliness of the workplace and the station

1. CLEANLINESS OF THE WORKPLACE AND THE STATION	3 POINTS: excellence	2 POINTS: Professional / Still acceptable (~80% Solution)	1 POINT: Optimization / rework necessary	0 POINTS: Not acceptable
Tools must not be left on the stations, chairs, or the floor of workspace.			 	
Unused components and workpieces must be removed from the stations.				
Stations must be free of waste, off-cuts or any other debris. This also includes the inside of cable channels.			 	
Unused parts have to be placed together on the table or in a box. Unused parts shall be separated from tools, waste, and consumables that the team have supplied. Also Documentation in EN have to be placed in the box			 	
Markings (tape, pencil, etc.) may be used during the tasks, but in that case, they must be removed completely before evaluation.				








<p>The floor of the workspace shall be clean from waste generated from the competitors work.</p>		
--	--	---



## 2. Routing of tubes and cables





2. ROUTING OF TUBES AND CABLES	3 POINTS:	2 POINTS:	1 POINT:	0 POINTS:
	excellence	Professional / Still acceptable (~80% Solution)	Optimization / rework necessary	Not acceptable
Cable, tubes and water piping must be routed separately. Optical cables may be tied to electrical cables. Exception to this rule when the cables and tubes are connected to a moving module. In this case routing all cables and tubes together is preferred.				
Remaining length of cut cable ties, A: $A \leq 1 \text{ mm}$				
All cables and tubes going downwards on a profile e.g. at the "Pick & Place" station have to be mounted with cable- holders and tie.				
Distance between cable ties: $\leq 50 \text{ mm}$ . This also applies to cables line under the profile plate.				

<p>The only acceptable method for binding Cable / Wire / Optical Cables / Tubes is to use cable holders. Cables and tubes shall be tightened to the cable holder. The cable tie shall go through both sides of the holder. For single wire it is allowed to use just one side.</p>		
<p>Distance between cable holders <math>\leq 120</math> mm Short connections between optical sensor and transmitter are also allowed. No coiling of the cables, if proper cut to length is possible. Exceptions can be announced in special cases.</p>		
<p>Conductors passing over DIN rails or routed around sharp corners must be secured using 2 cable holders.</p>		
<p>Airflow must not be restricted by kinks in the tubing, over-tight cable ties, etc.</p>		
<p>No pneumatic tubes routed through cable channels.</p>		




All cables and tubes routed through a flexible cable duct / drag chain must be fixed to the end of the chain, using cable ties.		
Distance from the shortest pneumatic connection to the first cable tie: 60 mm +/- 5mm Airflow must not be restricted		
Pneumatic and water connections must be leak-free.		
Bending radius of light conductor > 25 mm		<div data-bbox="1480 611 1615 727">Radius too small but sensor works</div> <div data-bbox="1630 624 1733 772"></div> <div data-bbox="1765 611 2024 699">Light conductor broken because of too small bending radius.</div>
Cables and tubes tied together do not cross each other more than necessary.		
















### 3. Mechanical Implementation


3. MECHANICAL IMPLEMENTATION	3 POINTS:	2 POINTS:	1 POINT:	0 POINTS:
	excellence	Professional / Still acceptable (~80% Solution)	Optimization / rework necessary	Not acceptable
All system components and modules must be secured. → Check by Hand of Expert				
All actors and workpieces have to move without collisions. Note: This must be noted by PLC evaluation team	Free movement of all actuators, cables, tubing and workpieces.	Minor collision, for example tubing touching a moving part, not affecting the function.	Major collision, for example if gripper crashes to the workpiece, or workpieces fall off the system.	
Adjoining stations must be connected with at least 2 connectors.				
All ends of profiles must be fitted with caps.				
Use min.at least 2 screws with washers to secure any section of cable channel. → Expert will open the cable channel to see that.				
Screw heads have to be undamaged.				



Saw-cuts must be burr-free.			
Parts of devices and components should not extend beyond the profile plate. Exceptions will be announced by the expert team.			
All components shown in the 3d sketches and photos have to be assembled and placed approximately in the designated area on the correct MPS Station / Trolley / Profile plate - function as intended		Missing component not affecting the function of the system.	Missing component affecting the function of the system.





## 4. Electrical installation and wiring of the components

4. ELECTRICAL INSTALLATION AND WIRING OF THE COMPONENTS	3 POINTS:	2 POINTS:	1 POINT:	0 POINTS:
	excellence	Professional / Still acceptable (~80% Solution)	Optimization / rework necessary	Not acceptable
All signal terminations must be secured. → Check by Hand of Expert				
Bare conductors must not be visible at end sleeves.				
Insertion of end sleeves into terminals			Uninsulated portion of end sleeve visible 	
Insulated end sleeves of the correct size for the wire must be used on all screw terminals Available sizes are: 0.25, 0.5, 0.75 mm² Exceptions for clamp connections (only for screws)			 	
Clamp type connections may be made without the use of end sleeves.	 		Bare conductors must not extend beyond terminal.  	

<p>Electrical cables must have a minimum of 100 mm reserve in the cable channel.</p> <p>Unnecessary when it is a bridge in the same cable channel.</p> <p><i>Expert will open the cable channel to see that.</i></p>		
<p>Outer cable insulation must not extend beyond cable channel.</p>		
<p>No damage to wire insulation or exposure of bare conductors.</p> <p>→ Check by Hand of Expert</p>		
<p>Conductors between cable channel and terminals must not cross.</p> <p>One sensor / actuator connection per cable duct slot is allowed.</p> <p>No wiring over components</p>		
<p>Loose ends of wire must be tied back to cable and must have the same length as used wires.</p> <p>Insulation must be left to prevent any contact being made.</p> <p>This applies both inside and outside of the cable channel.</p>		

<p>Cable channels must be completely closed with all teeth under the cover.</p>		
<p>Removal of cable channel teeth.</p> <p>Note: There will be no replacement of the channel.</p>		

## 5. Special cases, announced by experts and the overall impression

5. SPECIAL CASES, ANNOUNCED BY EXPERTS AND THE OVERALL IMPRESSION	3 POINTS:	2 POINTS:	1 POINT:	0 POINTS:
	excellence	Professional / Still acceptable (~80% Solution)	Optimization / rework necessary	Not acceptable
No parts or components should be lost or damaged during assembly of equipment. Note: This must be noted by the time keeper if replacements need to be supplied				
Competitors shall not work in a way where they risk injury to themselves, or other people. This includes the use of prohibited tools and cleaning with compressed air. Note: This must be noted by the time keeper and verified by the ESR for H&S.				
All warning labels must be affixed and in the specified positions.				
For the evaluation the profile plate has to be in the lowest possible position.				
It is not allowed to prepare workpieces with tape or similar additives. Note: This must be noted by PLC evaluation team Exceptions will be announced by the expert team.			 	

## 6. HMI - Design

6. HMI - DESIGN	3 POINTS:	2 POINTS:	1 POINT:	0 POINTS:
	excellence	Professional / Still acceptable (~80% Solution)	Optimization / rework necessary	Not acceptable
The colors of the Switches and push buttons match like in the T-description				
The forms match like in the T-description!				
The texts and Symbols match like in the T-description and ther is no overlap!				
All required componets are implemented like designed in the T-description!				
The elements are arranged like the desined grid!				
The over all impression of the HMI pages!				



READING



PROBLEM SOLVING